



DHS Compliance History January 2015 and Forward

[-click here to access licensing rules-](#)

2017

Visit 9/27/17	Unannounced Visit DHS PE	No Violations Found
Visit 5/17/17	Unannounced Visit DHS PE	No Violations Found
Visit 1/12/17	Unannounced Visit DHS PE	No Violations Found

2016

Visit 5/5/16	Unannounced Visit DHS PE	Violations Repaired: <i>Emergency Light Repaired & Light on Exit Sign Repaired</i>
Visit 4/27/16	Unannounced Inspection Fire	Violations Recorded: <i>Emergency light needs repair; Exit sign light needs repaired</i>
Visit 1/12/16	Unannounced Visit DHS PE	No Violations

2015

Visit 12/16/15	Scheduled Re-Evaluation DHS PE	No Violations
Visit 9/17/15	Unannounced Visit DHS PE	No Violations
Visit 4/23/15	Unannounced Visit DHS PE	No Violations